



RV SERVICES

1. An RV Service Pole must be set in minimum 2 bags of QuikCrete.
2. A 120-Volt receptacle is required it must be GFCI protected with a weatherproof enclosure. In use type. Extra Duty only type approved.
3. A 30 AMP 125 Volt Travel Trailer Receptacle and or 50 AMP 4 wire RV Receptacle may be installed and are not required to be GFCI protected. All other receptacles installed outdoors are required to be GFCI protected.
4. All wiring must meet the current National Electric Code.
5. An RV Service is allowed to have a 120-Volt receptacle that is not GFCI protected, but it must be the type designated for RVs with an "in use" weatherproof cover.
6. All RV service receptacles must have an "in use" weatherproof cover.
7. Required 25ft pole @ 4' 6" minimum in the ground.

Approved by Inspector: 06/13/2014

Last Updated: 8/18/2021

K:\Front Office\Templates\RV Service.pdf (CSR)

K:\Administrative\BCES Service Policies\Customer Reference Sheets\RV Service.ppt (Editable)